



# HDPE Pressure-Rated Pipe

## IPS Pipe Sizes

DIPS Size	Avg. OD	SDR PSI	7 335	7.3 320	9 250	11 200	13.5 160	15.5 139	17 130	19 110	21 100	26 80	32.5 65
¾	1.05	Min Wall Avg ID Weight p/ft	0.150 0.732 0.180	– – –	0.117 0.802 0.150	0.095 0.849 0.120	0.078 0.885 0.100	– – –	– – –	– – –	– – –	– – –	– – –
1	1.315	Min Wall Avg ID Weight p/ft	0.188 0.916 0.288	0.180 0.933 0.278	0.146 1.005 0.230	0.120 1.061 0.200	0.097 1.109 0.160	– – –	– – –	– – –	– – –	– – –	– – –
1 ¼	1.66	Min Wall Avg ID Weight p/ft	0.237 0.157 0.459	0.227 1.178 0.442	0.184 1.292 0.370	0.151 1.358 0.310	0.123 1.414 0.250	0.107 1.446 0.224	0.107 1.465 0.206	– – –	– – –	– – –	– – –
1 ½	1.90	Min Wall Avg ID Weight p/ft	0.271 1.325 0.600	0.260 1.348 0.580	0.211 1.478 0.480	0.173 1.554 0.400	0.141 1.618 0.330	0.123 1.654 0.295	0.112 1.676 0.270	– – –	– – –	– – –	– – –
2	2.375	Min Wall Avg ID Weight p/ft	0.339 1.656 0.939	0.325 1.685 0.906	0.264 1.815 0.760	0.213 1.917 0.640	0.176 2.002 0.530	0.153 2.069 0.458	0.140 2.078 0.430	0.125 2.110 0.390	0.113 2.135 0.350	– – –	– – –
2 ½	2.875	Min Wall Avg ID Weight p/ft	0.411 2.004 1.377	0.394 2.040 1.329	0.319 2.198 1.109	0.262 2.351 0.930	0.213 2.449 0.764	0.213 2.424 0.771	0.169 2.516 0.622	– – –	– – –	– – –	– – –

United Poly Systems Pressure Pipe is manufactured to the following standards: ASTM D3035, AWWA C901/C906, F714, D2513, F2619, NSF 61

